

Dr.-Ing. T. Bäumer

Prüflabor - Ingenieurbüro – Prüfstände

TEST Certificate

Fire Type Test according to DIN EN ISO 10497 Report IBB-2604

This report confirms the successful testing of a representative valve in compliance with DIN EN ISO 10497, 2010, and API 607, 7th edition.

Manufacturer	Armature d.o.o. Koroska cesta 55 2366 Muta, SI	Xomox International GmbH & Co. OHG Marburger Str. 364 57223 Kreuztal
---------------------	--	--

Test Valve	Crane® FK-TrieX 08RDL-AAA1-A-1AA-F Flange end connections, Gear operated Nominal bore: 8" Pressure rating: Class 300 Body/Bonnet material: A216 Gr. WCB Drawing Number: H19800052-b
-------------------	--

Date of Testing	23 March 2022
------------------------	---------------

Qualified sizes	DN 200 and above 8" and above
------------------------	----------------------------------

Qualified pressure ratings	Class 150, Class 300 PN 10, PN 16, PN 25, PN 40
-----------------------------------	--

Test requirements	The tests were carried out strictly in accordance with DIN EN ISO 10497, 2010, and API 607, 7th edition
--------------------------	--

Herford, 23 March 2022

Dr.-Ing. T. Bäumer
GmbH



Mr. Dr. T. Bäumer
Consultant engineer